

Canaseraga Central School District

Water Testing Results

March 2017.

The information included in this report detail the laboratory results from water samples taken from locations in the school district building. Any sample results with a reading of greater than **0.015** signifies a lead content beyond the NYS approved limit for school districts.

The following fixture was replaced. The lab results continue to indicate a higher than acceptable limit for lead in the water. Therefore, we will be exploring our options to remedy the supply lines for the fixtures that have high readings.

If you have any specific questions during the process, please don't hesitate to contact me directly. Thank you for your patience and understanding during the process.

Chad C. Groff
Superintendent of Schools
607-545-6421

Canaseraga Central School District
Water Testing Results
March 2017.

Site ID / Location
of Sample:

Kitchen Center Sink

Date:

2/23/2017

LSL ID #

> 00 / A

Original Sample
Results:

0.022

Remediation Plan for Outlet / Tap:

The District replaced this fixture and the lab results continue to yield a result higher than permitted. The District will seek to remedy the supply line to this fixture.

Was Outlet / Tap Taken Out of Service:

NO

Sample Results After Remediation:

N / A

Date:

N / A

*ALL laboratory testing was completed by Life Science Laboratories, Inc.
5854 Butternut Drive East Syracuse NY 13057 State Cert # 10248*